


PS ANEXT

Pair	Frequency	Value	Limit	Margin	Status
12	All test data above limit caps				PASS
36	434.0 MHz	64.82 dB	50.44 dB	14.38 dB	PASS
45	All test data above limit caps				PASS
78	441.0 MHz	62.82 dB	50.33 dB	12.49 dB	PASS
Average	All test data above limit caps				PASS

Disturber List
 U/FTP CAT6A 2
 U/FTP CAT6A 3
 U/FTP CAT6A 4
 U/FTP CAT6A 5
 U/FTP CAT6A 6
 U/FTP CAT6A 7



PS AACR-F

Pair	Frequency	Value	Limit	Margin	Status
12	All test data above significance condition				PASS
36	All test data above significance condition				PASS
45	All test data above significance condition				PASS
78	All test data above significance condition				PASS
Average	All test data above significance condition				PASS

Disturber List
 U/FTP CAT6A 2
 U/FTP CAT6A 3
 U/FTP CAT6A 4
 U/FTP CAT6A 5
 U/FTP CAT6A 6
 U/FTP CAT6A 7

